Building 49 Net Zero Building Analysis



2257 ~ 17334 sq. ft. 3 Floors 197 (studio) + 55 (lab/office)

35,

ŝ

[]

S



2022 TOTAL ANNUAL ENERGY USE 152, 407.1334 kWh









Third Floor





Second Floor



Desktop computers

Building 49 End Users



CFL Lights





Third Floor





9 C

9 C

9 Ē

Ð

œ

9 @

9 8

9 @

9 6

9 8

Building 49

Users

252

Ľ

2

Second Floor





First Floor



Occupancy

3 6

20 63

3 67

20 67

Ð

30

G

30 63

3 6

D 63

Ð

20



Peak load near the • beginning of the fall semester



8:00:00 AM

12:00:00 PM

4:00:00 PM

8:00:00 PM

4:00:00 AM

20000

15000

10000

5000

12:00:00 AM

kWh

- Peak load during ٠ studio times
- Largest loads are • the computer lab and studio load

OOOO

Che Ramsubhag and Christopher Stinson

User Load



Estimated Total Annual Energy Savings	70,565 kWh/year
Estimated Total Annual Energy Savings	\$7,056 /year

Che Ramsubhag and Christopher Stinson

00000

oad

₽

ມຊ

Strategy



SMART POWER STRIPS

These are power strips that automatically turn off power to devices that are not in use, eliminating standby power consumption.



OCCUPANCY SENSORS

These sensors detect when a room is empty and turn off power to devices, such as lights and fans, that are not needed.



TIMERS

These can be used to schedule devices, such as lights or appliances, to ensure they are only used when needed.



ENERGY MONITORING SYSTEMS

These systems track energy usage in real-time and provide feedback to users on how to reduce energy consumption

Strategy

Implementation of Solar Panels on Lake (Floatovoltaics)



Source: Solar Energy Research Institute of Singapore (SERIS) at the National University of Singapore (NUS)

Source: TERI

Miami experiences approximately 3154 sun hours annually

 A "Sun-Hour" is "1000 watts of energy shining on 1 square meter of surface for 1 hour"

0000000000000000000000



Strategy



Window Replacement

- All windows are currently fixed
- Operable windows can be used to naturally ventilate a space removing warm air and providing comfort, reducing the need for mechanical ventilation
- U-Value of 0.4 or less
- SHGC of 0.25 or less







Thank You